

DIVISION F2

DETAILED REQUIREMENTS

-
- Separate pricing for installation only of the second unit based on successful installation of the first unit. This shall be a separable portion of the work scope that may be awarded to others based on the success of the first installation.
 - Separate pricing for supply and installation of an overfire air system as detailed within these specifications.
 - Separate pricing for providing all required internal boiler access scaffold.
 - Separate pricing for providing just the external boiler access scaffold.
 - Separate price for preparation and operation of a boiler model showing anticipated location of highest CO accumulations within the boiler.
- e. Bidders shall submit a required access plan showing location and extent of all required scaffolding in the event the Owner elects to provide all required scaffolding.
8. Safety: The Contractor shall be responsible to provide and manage an acceptable safety program. For additional information see Division F1, Page F1-3, Article 6.
- a.. The Contractor shall provide a full-time Safety Representative. The Safety Representative shall act as the point of contact for all safety-related issues and may be assigned additional duties.
 - b.. The Contractor shall provide copies of written safety policies/plans to the Contract Administrator one (1) month prior to beginning work. These include, but are not limited to, Respiratory Protection, Confined Spaces, and Hazard Communication.
 - c. Prior to flame cutting or welding in any location, the Contractor shall first obtain a Hot Work Permit. This permit will be coordinated by the Contract Administrator or designee. The permit lists safety precautions which shall be taken before, during, and after hot work. The Contractor shall ensure all contract personnel comply with the conditions of the permit.
 - d. The Contractor shall ensure that its employees perform work in accordance with all applicable federal, state, and local safety and health regulations. The IPSC Safety Section personnel will periodically monitor the job site. If violations are noted, they will be reported to the Contractor's onsite Supervisor and the Contract Administrator for appropriate action. **Note: Except in the event of an emergency, only the Contract Administrator has authority to direct the Contractor's actions or obligate IPSC.**
 - e. The following table is a list of anticipated safety hazards and personal protective equipment needed in the contract area. This must not be considered a complete listing of all potential hazards. The Contractor shall provide appropriate personal protective equipment to its employees to protect against these hazards and others as they are identified :